

**CHECKLIST** (to be completed by site manager/supervisor)

Company: \_\_\_\_\_

Site: \_\_\_\_\_

Plot: \_\_\_\_\_ Site manager/supervisor: \_\_\_\_\_

Ref.	Item	Yes (✓)	No (✓)	Inspected (initials & date)
1.	Has training been received from Icopal-MONARFLOOR®	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
2.	Are precast concrete planks 150mm (min) thick and of mass per unit area 300 kg/m <sup>2</sup> (min)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
3.	Are inner leaves to external (flanking) walls of the correct block density?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
4.	Are joints between precast concrete planks grouted and sealed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
5.	Are precast concrete planks built into the masonry walls?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
6.	Is the 10mm TRANQUILT® covering the whole floor slab?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
7.	Is the TRANQUILT® taken 150mm up the wall?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
8.	Are the integrated overlaps sealed with Monarfloor Acoustic Adhesive?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
9.	Are the skirting boards and wall linings isolated from the screed by the TRANQUILT®?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
10.	Has the installation been signed off by Icopal-MONARFLOOR® prior to pouring the screed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
11.	Are all ceiling board joints sealed with tape or caulked with sealant?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
12.	Are service pipes wrapped in quilt and boxed in with two layers of nominal 8 kg/m <sup>2</sup> gypsum-based board?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
13.	Is separating floor satisfactorily complete?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>

Contact details for technical assistance from Icopal-MONARFLOOR® TRANQUILT®, manufacturer of TRANQUILT® resilient layer system:  
**Telephone: 0161 866 6540      Fax: 0161 866 6527      E-mail: [acoustics.uk@icopal.com](mailto:acoustics.uk@icopal.com)**

**Notes** (include details of any corrective action)

Site manager/supervisor signature .....

© UK registered trade mark no. 2291665

© Robust Details Limited 2011. All rights reserved. No part of this Handbook (other than the checklists) may be reproduced in any material form or issued or communicated to the public (including photocopying or storing it in any medium by electronic means, and whether or not transiently or incidentally to some other use of this Handbook) without the prior written permission of Robust Details Limited except in accordance with the provisions of the Copyright, Designs and Patents Act 1988.

Warning: the doing of an unauthorised act in relation to a copyright work may result in both a civil claim for damages and criminal prosecution.